

COMPLETED FORM TO BE RETURNED WITH THE APPLICATION (revised 6/01)

ARM 37.100.141 FIRE SAFETY	YES	NO
1. Smoke detector on each level of the building		
Approved by recognized testing laboratory		
Properly maintained and regularly tested		
Mobile homes have smoke detectors near all sleeping areas		
2. A workable portable fire extinguisher on each level		
Minimum rating of 2A10BC		
Mounted on a wall		
3. No unvented fuel-fired heating devise		
4. No stove or combustion heater is located as to block escape from building in the event of malfunctioning of the stove or heater.		
5. Every room used for sleeping, living or dining has 2 exits		
At least 1 exit shall be a door or stairway providing a means of unobstructed travel to the street or ground level outside of the building.		
All exits are unobstructed, easily traveled condition, free of ice and snow on the outside.		
If basements are regularly utilized for resident activities, there shall be 2 exits		
Doors which form a part of a required exit are at least 36 inches wide in new construction, and at least 30 inches wide in existing facilities and insure adequate width for residents in wheelchairs.		
Traffic to and from any room is not through a resident's bedroom.		
The first floor of a foster home has at least 2 separate and independent exits leading to the outside.		
Homes with residents in wheelchairs are equipped with ramps at each exit to the outside. A ramp shall not exceed 1 foot of rise in 12 inches of run.		
No path of travel to the outside is through a room(s) that are locked or otherwise controlled by a person other than the person seeking to exit the building.		
No occupied room shall have as its means of access a trap door, ladder or folding stairs.		
Every door that can be locked shall have a means to open the door from the outside in case of emergencies. Closets ____ Bathrooms ____		
For Initial Licensure: Pursuant to ARM 37.100.140 Inspection date and outcome of woodburning stove inspection (attach documentation). NOTE: if the local fire officials are unable or unwilling to inspect your stove, you are encouraged to contact an area wood stove dealer for a list of recommended inspectors. e.g. Certified chimney sweeps are an acceptable resource.		

Applicant's signature: _____ Date: _____